

# WARNING NOTICE

FORSYTH COUNTY  
DEPARTMENT OF ENGINEERING  
770-781-2165

## NOTICE TO COMPLY WITH SOIL EROSION CONTROL

This is to Inform: LARRY Oldham

Phone #: \_\_\_\_\_ Fax #: 770-888-4988  
that your site at: Subdivision: High Gables Lot #: 38  
Street Address: 4250 High Gables EAST  
Permit #: \_\_\_\_\_

Is out of compliance with the SOIL EROSION AND SEDIMENTATION CONTROL ordinance and/or the Forsyth County Zoning and Land Use Resolution and/or the Georgia Erosion and Sedimentation Act of 1975, as amended; In that

These are the noted non-compliance issues:

- No Permit Posted
- Violation of Ordinance 73
- BMP's must be installed
- Silt fence must be DOT approved
- Silt fence must be Type "C"
- Silt fence has not been maintained
- Remove mud out of the road
- Construction exit:  
(50' x 20' x 6" Minimum,  
using #3 or #4 rock or larger with a  
Geotextile Underliner
- Mulch all disturbed area  
(2" minimum)
- Other:

NEED MORE GRAVEL TILL PAVED

CORRECTIVE ACTION MUST BE TAKEN PRIOR TO: 8-16-05  
Or a STOP WORK NOTICE WILL BE ISSUED! When a STOP WORK NOTICE is issued, ALL WORK, except correcting the noted problems will have to stop! The Forsyth County Chief Building Inspector will be so notified. MANDATORY FINE(S) WILL BE INCURRED.

If you have any questions or need any help please contact: LARRY  
8-9-05 9:30 [Signature]  
DATE AND TIME OF INSPECTION INSPECTOR

HAND DELIVERED: \_\_\_\_\_ DATE AND TIME RECEIVED \_\_\_\_\_ OWNER (or authorized agent) \_\_\_\_\_

FAXED: \_\_\_\_\_ DATE SENT/INITIALS OF SENDER \_\_\_\_\_ MAILED: \_\_\_\_\_ DATE SENT/INITIALS OF SENDER \_\_\_\_\_

WHITE - Individual      YELLOW - File      PINK - Engineering      GOLDENROD - Site